

**CITY OF VESTAVIA HILLS
SICARD HOLLOW ATHLETIC COMPLEX- PARK IMPROV. PHASE 3
VESTAVIA HILLS, ALABAMA**

HNP C019005

5 August 2019
ADDENDUM NO. 4
Specifications of the Contract Documents
City of Vestavia Hills
Sicard Hollow Athletic Complex - Park Improvements Phase III



This Addendum is hereby made a part of the Contract Documents to the same extent as though it was originally included therein. Receipt for this Addendum must be acknowledged by the Bidder by statement of receipt indicated on the Proposal Form.

QUESTIONS

1. Question: Can excess soils remain on site, if not does the owner have a dump site that is available?
Answer: The Owner will designate an area on site for excess soils. After placement, the area is to be graded and seeded.
2. Question: In regards to the pavilion, are the sidewalks to pavilion and slab/apron under the pavilion in base bid and footings, rock and concrete precast in alternate?
Answer: the walk to the courts is base bid. The pavilion footings, the slab under the pavilion, the rock and precast at the columns is in the alternate.

End of Addendum