

To : All Prospective Bidders  
City of Montevallo - **George Dailey Park**

**Addendum No. 3**

October 5, 2020

Changes and modifications set forth in this Addendum and detailed below shall become a part of the Project Specifications, Bid Documents, and Contract Documents for the above referenced project.

The following is an itemized list of changes, corrections and clarifications to the Bid Documents dated September 18th, 2020. All Bidders are to acknowledge receipt of this Addendum on 'Proposal Form'.

**Project Manual**

( No additions or changes )

**Specifications**

(No additions or changes )

**Plans:**

- A) *Sheet L1.5, detail No. 1*** : delete tinted/colored concrete reference. Concrete to be natural concrete color.
- B) *Sheet L1.6, details*** : The base bid Poured in-place "Fall Material", called out on the drawings is to not be less than 4" deep in the Fall zones and may be "feathered out/thinned" to a minimum depth of 2 to 2-1/2" in the non- fall zone areas. The Alternate Wood Carpet/ EWF "Fall Material" is to not be less than 12" settled depth in all areas.

**General Clarifications :**

- A) The Bid Date for the project is October 6, 2020 by 2:30pm for both(2) packages and are to be delivered to Montevallo City Hall to the attention of the City's Clerk, Herman Lehman.

**Attachments :**

( None )

Kelly Landscape Architects, Ilc.

**End of Addendum No. 3**